

John Ruskin Primary School John Ruskin Primary School John Ruskin Street LONDON SE5 0PQ	Operational rating <div>E</div>	Certificate number: 0776-4243-4127-6032-0750
		Valid until: 31 January 2024
		Total useful floor area: 3359 square metres

Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO2) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	A		
26-50	B		
51-75	C		
76-100	D		
101-125	E	108 E	100
126-150	F		
150+	G		

This building's energy use		
Energy use	Electricity	Other fuels
Annual energy use (kWh/m2/year)	37.08	156.71
Typical energy use (kWh/m2/year)	40	128.56
Energy from renewables	0%	0%

Previous operational ratings	
Date	Operational rating
February 2023	108 E
February 2022	101 E
February 2021	97 D

Total carbon dioxide (CO2) emissions			
This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO2.			
Date	Electricity	Heating	Renewables
February 2023	68	102	0
February 2022	68	100	0
February 2021	59	96	0

Assessment details	
Assessor's name	James Rankin
Employer/Trading name	Clifton Energy
Employer/Trading address	New House Farm, Antlands Lane, Burstow, Horley, Surrey, RH6 9TF
Assessor's declaration	Not related to the occupier.
Accreditation scheme	Sterling Accreditation Ltd
Issue date	30 March 2023
Nominated date	1 February 2023

