

Display energy certificate (DEC)



HM Government

John Ruskin Primary School
John Ruskin Primary School
John Ruskin Street
LONDON
SE5 0PQ

Operational rating

E

Certificate number: 0777-2265-0177-0008-2630

Valid until: 31 January 2025

Total useful floor area: 3,359 square metres

Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO₂) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	A		
26-50	B		
51-75	C		
76-100	D		
101-125	E	107 E	100
126-150	F		
150+	G		

Previous operational ratings

Date	Operational rating
February 2024	107 E
February 2023	108 E
February 2022	101 E

Total carbon dioxide (CO₂) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO₂.

Date	Electricity	Heating	Renewables
February 2024	78	92	0
February 2023	68	102	0
February 2022	68	100	0

Assessment details

Assessor's name	James Rankin
Employer/Trading name	Clifton Energy
Employer/Trading address	New House Farm, Antlands Lane, Burstow, Horley, Surrey, RH6 9TF
Assessor's declaration	Not related to the occupier.
Accreditation scheme	Sterling Accreditation Ltd
Issue date	15 October 2024
Nominated date	1 February 2024

This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m ² /year)	42.16	141.75
Typical energy use (kWh/m ² /year)	40	131.65
Energy from renewables	0%	0%

